

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Unsatisfactory

Permit Number: 13-51-15739
Name of Facility: Dr. Rolando Espinosa K-8 Center
Address: 11250 NW 86 Street
City, Zip: Doral 33178

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Maria Munoz Phone: 305 559 5757

Correct By: by 8:00 AM
Re-Inspection Date: 3/10/2016

Inspection Information

Purpose: Complaint
Inspection Date: 3/3/2016

Begin Time: 02:00 PM
End Time: 04:30 PM

Additional Information

CENSUS	1717
FEMALES	798
MALES	919

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

SCHOOL SANITATION	<input checked="" type="checkbox"/> 11. Cleanliness & Repair	22. Solid Waste
1. School Site	12. Toilet Facilities	VECTOR/VERMIN CONTROL
2. Playground Equipment	13. Separation of Sexes	23. Infestation/Control
3. Athletic Equipment	14. Fixture Ratio	24. Brush/Trash
BUILDINGS	15. Handwash Facilities	25. Water Collection/Drainage
4. Construction	16. Showers/Fixtures	SAFETY
5. Maintenance & Repair	17. Shower Water Temp.	26. First Aid Kit
6. Lighting/Foot-Candles	WATER SUPPLY	FOOD
7. Heating, Ventilation, A/C	18. Installed/Operated/Maintained	27. Food Insp. Rpt.
8. Natural Ventilation	19. Drinking Fountains	OTHER
9. Mechanical Ventilation	20. Approved Source	28.
SANITARY FACILITIES	LIQUID/SOLID WASTE	29.
10. Provided/Accessible	21. Sewage Disposal	

General Comments

Complaint valid. The valid complaint is related to hygiene.
No roaches or roach droppings were observed. No live activity present at the time of inspection.

Email Address(es): slnelson@dadeschools.net;mmunoz@dadeschools.net;ipalacio@dadeschools.net;tequigley@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #11. Cleanliness & Repair
Clean the floors of all restrooms throughout the school. Observed dirt on the floors.
CODE REFERENCE: Cleanliness & Repair 64E-13.004(6)(a). Walls to a height of at least 4' feet toilet partitions and floor of all toilet rooms shall be finished with impervious materials. All plumbing fixtures shall conform to the provisions of the local plumbing code. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Deodorizers shall not be used in toilet rooms.

Inspection Conducted By: Maria Moreno (27482)
Maria Moreno
Date: 3/3/2016

Inspector Signature:

Handwritten signature of Maria Moreno.

Client Signature:

Handwritten signature of Dr. Rolando Espinosa.